NEW YORK STATE OF OPPORTUNITY. | Office for People With Developmental Disabilities

KATHY HOCHUL
Governor

WILLOW BAER
Acting Commissioner

September 18, 2024

Re: **2025-2030 Campus Chiller Inspection, Maintenance, Repair and Replacement Services in Rockland County IFB HV 100224**

Questions and Answers:

Below is a compilation of the questions received for this bid. Questions that were repeated, or of a recurring nature, were consolidated. Thank you for your interest.

1. **Question: When was the last time eddy current testing was done?**

   Answer – OPWDD does not have a record of the last time eddy current testing was done.
   But OPWDD has always operated the unit to the manufacturer's specification.

2. **Question: During the tube punch down / cleaning, do they remove both bulk heads or just one?**

   Answer – When doing the tube punch down / cleaning, the vendor only must remove one bulkhead, but they must replace the seal and gasket at that time.

Respectfully,

Michael J. Keller, CMS 1
Contract Management Unit
(845) 877-6821 ext. 3025
(845) 877-3044 (fax)
Michael.j.keller@opwdd.ny.gov